

CORRIGENDUM-I

AMENDMENT OF TENDER NOTICE NO.NESCO/O&M Materials/58/8267 Dt.17.07.2015 on TECHNICAL SPECIFICATION OF LIGHT FITTING GROUP

G

Sl.No.	Page No.of Technical Specification of LIGHT FITTING Group-G in above refered Tender	Reference of Caluse of GTP of Group G in above refered Tender	Description of Caluse of GTP of Group G in above refered Tender	Amendments as.
1	2	In Material Description Table 1st Row 2nd Column	2x40 W florescent light fittings	2x40 W florescent light fittings for Control Room
2	2	In Material Description Table 2nd Row 2nd Column	C	LED light fittings (48 W) for 33/11KV Structure Lighting
3	4	TECHNICAL SPECIFICATION OF LED LIGHT Clause 2.0	2.0 TECHNICAL REQUIREMENT FOR LED STREET LIGHTS	2.0 TECHNICAL REQUIREMENT FOR LED LIGHTS
4	4	TECHNICAL SPECIFICATION OF LED LIGHT Clause 2.0	2.1 GENERAL: Application: Street Lighting	2.1 GENERAL: Application: 33/11KV Structure Lighting
5	5	Clause 2.5, Sub Clause f.	f."Not for sale - BEE's LED Village Campaign, Odisha".	Deleted
6	6	2.13 SWITCHING:	2.13 SWITCHING: Photosensitive automatic switching device for operation in night hours only. Additional manual control mechanism to be also provided and manual control should always prevail over the auto control.	2.13 SWITCHING: Manual Control
7	6	Clause 3.0	3.0 GENERAL REQUIREMENTS FOR BOTH HOME LIGHTING AND VILLAGE STREET LIGHTING:	3.0 GENERAL REQUIREMENTS FOR 33/11KV STRUCTURE LIGHTING:

8	6	Clause 3.0, I.	I.Only NICHIA/ OSRAM/ SEOUL/ PHILIPS/ LUMILEDS/ LEDNIUM/CREE LED's shall be used for the LED lamps and street lights.	I.Only NICHIA/ OSRAM/ SEOUL/ PHILIPS/ LUMILEDS/ LEDNIUM/CREE LED's shall be used for 33/11KV Structure Lighting.
9	6	Cause 3.0, III (4th point)	The junction temperature of the Switching devices such as transistors and MOSFETs etc. shall not exceed 125°C (allowing thermal margin of 25 °C).	Deleted
10	7	Clause 3.0, IX	IX. The manufacturer /firm should also offer Annual Maintenance Contract (AMC) package(s) for the post Warranty period.	Deleted
11	7	Clause 3.0, X	X.All the supplied lamps, luminaries and fittings shall carry permanent marking as "Not for sale - BEE's LED Village Campaign, Odisha" .	Deleted
12	8	Clause 5.0, Sub Clause 5.2	5.2 The PURCHASER may at its option get the materials inspected by the third party if it feels necessary	Deleted
13	9	Heading of GTP	GUARANTEED TECHNICAL PARTICULARS (LED STREET LIGHT) (TO BE SUBMITTED BY THE BIDDER)	GUARANTEED TECHNICAL PARTICULARS (LED LIGHT WITH FITTING FOR STRUCTURE LIGHTING) (TO BE SUBMITTED BY THE BIDDER)
14	9	18th Row of GTP Table	17.Automatic ON and OFF switching device with photosensors- Required.	Deleted

DGM(C&P)
NESCO UTILITY